

Emission Test Certificate

Friday, 14th January, 2010

Supplier: Gerfloor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123)

Sample Description: Creation Clic Flooring

Date Tested: December 2010

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2/V3 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p align="center">Creation Clic</p>
<p>Total Volatile Organic Compound emission rate < 0.5 mg/m²/hr (24 Hours)</p>	<p>Total Volatile Organic Compound emission rate 0.06 mg/m²/hr (24 Hours)</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV101219