

Emission Test Certificate

Friday, 14th January, 2010

Supplier: Gerfloor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123)

Sample Description: Saga² Flooring

Date Tested: December 2010

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Specification Green Building Council of Australia Green Star Office Design V2/V3 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Saga²
Total Volatile Organic Compound emission rate < 0.5 mg/m ² /hr (24 Hours)	Total Volatile Organic Compound emission rate 0.02 mg/m ² /hr (24 Hours)



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV101219