

Emission Test Certificate

Tuesday 02nd April 2019

Supplier: Gerflor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123, Australia)

Sample Description: Gerflor Tarasafe Ultra H₂O

Date Tested: March 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p>Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p>Gerflor Tarasafe Ultra H₂O</p>
<p>Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$</p>	<p>Total Volatile Organic Compound Emission Rate: $0.266 \text{ mg/m}^2/\text{hr}$</p>
<p>Formaldehyde Emission Rate Limit: $\leq 0.1 \text{ mg/m}^2/\text{hr}$</p>	<p>Formaldehyde Emission Rate: $0.013 \text{ mg/m}^2/\text{hr}$</p>



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Nick Joy
 BSc(Hons)
 Consultant



Tuan Duong
 B.Eng. (Chemical)
 Consultant

CV190328