

Emission Test Certificate

Thursday September 22nd, 2011

Supplier: Gerflor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123)

Sample Description: Taralay Premium Compact Flooring.

Date Tested: July 2011

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

| | |
|--|--|
| Specification Green Building Council of Australia Green Star Office Design V2/V3 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 | Taralay Premium Compact |
| Total Volatile Organic Compound emission rate $<0.5 \text{ mg/m}^2/\text{hr}$ (24 Hours) | Total Volatile Organic Compound emission rate $0.085 \text{ mg/m}^2/\text{hr}$ (24 Hours) |



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

CV110717a